

DEPARTMENT OF TRANSPORTATION - District 4 Toll Bridge Program

333 Burma Rd.
Oakland, CA 94607
(510) 286-0538, (510) 286-0550 fax



Kiewit-FCI-Manson, JV
220 Burma Rd.
Oakland, CA 94607

March 16, 2006

Contract No. 04-0120E4
04-SF-80-13.4, 13.8
SAS T1 & E2 Foundations
SFOBB-ESSSP

Attn: Mr. Christopher Villa
Deputy Project Director

Letter No. 05.003.01-000925

Subject: Response to Submittal No. 67, Revision No. 01 (CIDH Pile Placing Plan - Part A - Temp. Casing Support System)

Dear Christopher,

The Department has reviewed KFM Submittal No. 67, Revision No. 01, dated March 7, 2006, which provided the temporary casing support system for the Pier T1 CIDH pile placing plan. Regarding this Submittal, it is incomplete per the requirements of Section 10-1.24 "Piling" of the Special Provisions. This Submittal provided the plans and supporting calculations for the Pier T1 temporary casing support system but not the revised construction process. In addition, the Detail D of Drawing No. 04-079A-07 indicates a 1/2" fillet weld between the top flange of the W36 and the splice plate, but the calculations indicate a 3/4" weld. Please revise and resubmit the Pier T1 CIDH pile placing plan for the Department's review.

If you have any questions or need additional information, please contact Mark Vilcheck at (510) 286-0526.

Sincerely,

<<< ORIGINAL SIGNED >>>

Mark Vilcheck
Structure Representative

For: Pedro J. Sanchez
Resident Engineer

cc: P. Sanchez
M. Woods
S. Soheilifard
J. Duxbury

file: 05.003.01, 42.006.03, 55.067